

# TEXAS DEPARTMENT OF INSURANCE

Engineering Services / MC 103-3A 333 Guadalupe Street P.O. Box 149104 Austin, Texas 78714-9104  
Phone No. (512) 322-2212 Fax No. (512) 463-6693

---

## PRODUCT EVALUATION WIN-557

December 1, 2005

*The following product has been evaluated for compliance with the wind loads specified in the **International Residential Code (IRC)** and the **International Building Code (IBC)**. This product shall be subject to reevaluation 3 years after the effective date.*

*This product evaluation is not an endorsement of this product or a recommendation that this product be used. The Texas Department of Insurance has not authorized the use of any information contained in the product evaluation for advertising, or other commercial or promotional purpose.*

*This product evaluation is intended for use by those individuals who are following the design wind load criteria in Chapter 3 of the IRC and Section 1609 of the IBC. The design loads determined for the building or structure shall not exceed the design load rating specified for the products shown in the limitations section of this product evaluation. This product evaluation does not relieve a Texas licensed engineer of his responsibilities as outlined in the Texas Insurance Code, the Texas Administrative Code and the Texas Engineering Practice Act.*

**Series 8000C Vinyl Fixed Windows, Non-impact Resistant, manufactured by**

**Modern Window and Doors, Inc.  
2200 Spring Street  
Hot Springs, Arkansas 71901  
(800) 835-8998**

will be acceptable in designated catastrophe areas along the Texas Gulf Coast when installed in accordance with the manufacturer's installation instructions and this product evaluation.

## PRODUCT DESCRIPTION

The Series 8000C window is a vinyl fixed window. The fixed window evaluated in this report is an individual, non-impact resistant window. This product evaluation report is for a vinyl fixed window based on the following tested construction:

### General Description:

System	Description	Label Rating
1	Series 8000C; Individual Fixed Window; (O)	F-R65 54 x 74

### Product Dimensions:

System	Overall Size
1	53 1/2" x 74"

### Glazing Description:

System	Glass Construction <sup>1</sup>	Glazing Method <sup>2</sup>
1	IG-1	GM-1

Note: <sup>1</sup> See the "Glass Description Key" for the glazing construction.

<sup>2</sup> See the "Glazing Method Key" for the glazing method description.

**Glazing Description Key:**

IG-1: The window contains a sealed insulating glass unit. The sealed insulating glass unit is comprised of two double strength ( $\frac{1}{8}$ " ) annealed glass lites separated by a Truseal Swiggle™ spacer system.

**Glazing Method Key:**

GM-1: The insulating glass unit is set from the exterior against silicone backbedding. A rigid vinyl snap-in glazing bead secures the insulating glass units from the exterior.

**Frame Construction:** The frame members are manufactured from extruded vinyl (PVC). The frame corners are mitered and welded construction.

**Reinforcement:** None.

**Product Identification:** A certification program label will be affixed to the window. The certification program label includes the manufacturer's name, performance characteristics and approved inspection agency to indicate compliance with the requirements of AAMA/NWWDA 101/I.S.2.

**LIMITATIONS**

**Design pressures:**

System	Maximum Width (in.)	Maximum Height (in.)	Design Pressures (psf)
1	53 $\frac{1}{2}$	74	± 65

**Impact Resistance:** These window assemblies do not satisfy the Texas Department of Insurance's criteria for protection from windborne debris. These window assemblies will need to be protected with an impact protective system when used in areas where windborne debris protection is required.

**Acceptance of Smaller Assemblies:** Window assemblies with dimensions equal to or smaller than those specified above are acceptable within the limitations specified in this report.

**INSTALLATION INSTRUCTIONS**

**General:** The window assembly shall be installed in accordance with the manufacturer's installation instructions. The wood wall framing members shall be minimum Southern Yellow Pine lumber.

**Installation:** The window shall be mounted to the wood wall framing members using the frame of the window with minimum No. 8 screws. The fasteners shall be spaced a maximum of 4  $\frac{1}{2}$  inches from each corner and a maximum of 15 inches on center along the perimeter of the window frame. The fasteners shall be long enough to penetrate a minimum of 1  $\frac{1}{2}$ " into the wall framing members.

**Note:** The manufacturer's installation instructions shall be available on the job site during installation. All fasteners shall be corrosion resistant as specified in the International Residential Code (IRC), the International Building Code (IBC), and the Texas Revisions.